

The request for clarification of the Bidding documents

Subject: The answer to the question for IOP/2 - 2014 whose subject is Execution of works on the construction of Centres of excellence in Kragujevac.

**1. Question:**

Please tell us define the thickness of sheet lead in relation to the position of the door and window protection against X-ray radiation (AC Locksmith, positions 07-05 and 07-06 )

**Response:**

The exact dimensions of the sheet of X-ray space will be known only after the decision of investors to be the exact type of equipment purchased from any manufacturer and of which depends on the thickness of sheet lead. Generally the thickness of sheet lead will be in the range of 1mm - 3mm.

President of the Commission

  
Olja Jovanovic, BSc. Arch.