

The request for clarification of the Bidding documents

Subject: The answer to the question for IOP/2 - 2014 whose subject is Execution of works on the construction of Centres of excellence in Kragujevac.

1. Question:

In part 3. The capacity of the equipment , it is required that the bidder should possess or provide access to equipment that fully must be ready for the start of the works , that he plans to use during the works. Among other things, required under number 2. SKIP crane and number 3. Plastering machine. We ask for an explanation of what is meant by SKIP crane and whether plastering machine can be concrete mixer.

Response:

Skip crane is line crane which is driven by electric motors.

Mixer for the mortar is also concrete mixers

President of the Commission
Olja Jovanovic, BSc. Arch.

