



The request for clarification of the Bidding documents

Subject: The answer to the question for IOP/2 - 2014 whose subject is Execution of works on the construction of Centres of excellence in Kragujevac.

1. Question:

In Part bill of Boiler - gas installations::

Position 1.01. is not defined by the number of lines KMRS G - 100. Please clarify whether the aforementioned KMRS single line or two-line?

Response:

KMRS G - 100 is a single-line. Everything is given in figure KMRS from the Main boiler project, 2014UO18M03-08.

President of the Commission

Olja Jovanovic, BSc. Arch.