



The request for clarification of the Bidding documents

Subject: The answer to the question for IOP/2 - 2014 whose subject is Execution of works on the construction of Centres of excellence in Kragujevac.

1. Question:

Position 02-02, item 4, mounting partitions, 01-AC Works - Is it a priority to comply with the required fire resistance of the wall F120, given wall thickness $d=16\text{cm}$ or described circuit wall (double-layer fireproof plasterboard $d=2 \times 1,25\text{cm}$ + galvanized steel substructure $d=7,5\text{cm}$ filled with slabs of stone wool $d=7\text{cm}$, 100kg/m^3 + double-layer fireproof plasterboard $d=1,25\text{cm}$) making a total of $d=12,5\text{cm}$.

Response:

It is necessary to comply with the required fire resistance of the wall F120, accurately, given wall thickness $d=16\text{cm}$.

2. Question:

Position 02-02, items 8 and 9, mounting partitions, 01-AC works - Please define the thickness of lead foil / metal sheet.

Response:

The thickness of a lead foil is 1mm, for the device which is provided by the project.

3. Question:

Position 01-13, 4a_ Bill alongside the Main Project of external decoration with the landscaping-external works. Please provide us with a detailed description and graphic documentation related to sculpture.

Response:

Offer to give as described in the Main Project and Bill of works.

President of the Commission

Olja Jovanovic, BSc. Arch.