

CLARIFICATION no. 10

Procurement number N/R/02/16

Published on November 7th 2016

Regarding the request for additional clarifications of the tender documents for the procurement no. N/R/02/16 - Performing construction, reconstruction and renovation works for the third group of schools within School Modernisation Programme – Component 3, we submit the following answers:

1. BIDDER'S QUESTION:

Will the bidder fulfil the requirement regarding business capacity if the contract for reference building was signed within the required period (2011-2015), but works were completed in 2016, before the publication of the public procurement?

ANSWER:

The answer is yes.

2. BIDDER'S QUESTION:

Elementary school Veljko Vlahovic Novi Sad - Bill of quantities, construction craft works, XII FLOOR LAYING WORKS

In the Bill of quantities it is stated: Vinyl floors with holker batten made of the same material as floors. Sports vinyl floors are heterogeneous and not installed with holker batten. Installation of the floor - to the wall, and then placement of PVC batten (height 40-100mm). We need further clarification regarding batten.

ANSWER:

PVC batten, height 6cm, length 101,36m'.

3. BIDDER'S QUESTION:

Elementary School "Novak Radonic" Mol - Bill of quantities, construction craft works, VI Joinery

Descriptions for position 1 windows as well as position 2 doors are not aligned with the schemes which have been submitted. According to the Bill of quantities windows and doors are made of PVC profiles. According to the schemes they are wooden windows and doors or a combination of wood and aluminium.

We would like to know whether windows and doors are made of PVC, wood or wood-aluminium.

ANSWER:

Originally, in the project technical documentation windows were made of wood and aluminium. Subsequently, at the request of investors they have been changed to six-chamber PVC profiles. The shape and dimensions remain same as those in the schemes of joinery. All descriptions in the Bill of Quantities are valid.

Deputy president of Procurement Committee


Maja Pantić