

With regard to your Request for Clarification regarding tender dossier for procurement of 302 Packages of Building Material, within the framework of subproject III of the Regional Housing Programme, reference no. RHP-W3-CM/IOP1-2016, we provide the following clarification:

Request for Clarification:

(Filed under number 3933 from 06. July 2017. godine)

1. In Annex 2 under the serial number: 10.4. E 4, it is envisioned that it is necessary 133 pcs. of "Junction board (for flat) for wall mounting with transparent door, with space for 18 modules, DIN rail, IP40

Junction board contains:

The junction boards and equipment						
10.4	E	4	Junction board (for flat) for wall mounting with transparent door, with space for 18 modules, DIN rail, IP40 Junction board contains:	kom/pcs	-	133,00
			Single-pole fuse (Automatic fuse) for mounting on DIN rail nom. voltage 230V/400V, 50Hz, features B; breaking capacity 6kA:	/	/	/
			rated current of 6A	/	/	/
			rated current of 10A	/	/	/
			rated current of 16A	/	/	/
			The indicator lamp for signaling rates 230V for use in flat junction board, mounting on DIN rail	/	/	/
			FID switch for installation in junction board, mounting on DIN rail	/	/	/
			16A/30mA, 2-pole, 230V, 50Hz;	/	/	/
			25A / 0,5 A, 4-pole, 230V/400V, 50Hz;	/	/	/
			Bell 230V, 50Hz, for use in junction board, mounting on DIN rail	/	/	/

It is unclear whether and how much equipment must contain flat junction board (which has 133 pieces), since that the fields, i.e. columns with the quantities are empty?

Answer:

The junction board should contain the equipment with the quantities defined in the technical specification of the equipment, i.e. the junction board and supporting equipment represent the so-

called "complete position." Each of the 133 junction boards should include supporting equipment in the quantities defined in the equipment specification.

Procurement Committee Chairman



Predrag Knežević