

**CORRIGENDUM NO. 2 OF TENDER DOSSIER FOR THE PROCUREMENT OF:
EXECUTION OF WORKS ON THE CONSTRUCTION OF RESIDENTIAL
BUILDINGS, PUBLICATION REFERENCE: RHP-W5-AB/IOP2-2017**

Tender dossier for the procurement of: Execution of works on the construction of residential buildings, publication reference: RHP-W5-AB/IOP2-2017, is being modified in Volume 3 – Bill of quantities and Volume 4 – Desing documents, including technical drawings, Veternik, block 1,2 and 3, as follows:

1. Position 02-05 FLAT PASSABLE ROOF:

- Instead of waterproofing type SikaPlan G15, waterproofing type SikaPlan U15 is being added;
- Instead of thermal insulation type stone wool, thermal insulation type XPS is being added;
- As a separating layer between the HI and the cementitious layer, a layer of Geotextile and PE foil is being added;
- Instead of Penetrate, a polimeric coating of type Sikalastic 1K is applied.

2. Position 02-16 THERMAL INSULATION ON A FLAT IMPASSABLE ROOF

Taking into account the changes of the thermal insulation on a flat passable roof, position 02-16 is being divided into 2 positions: 02-16 and 02-16a:

- Position 02-16 stays as the position for flat IMPASSABLE ROOF with all descriptions and quantities **that do not change (remain the same)**;
- Position 02-16a is being added, where the stone wool is being replaced with thermal insulation XPS, in accordance with the changes under the position 02-05.
-

Tender dossier – Graphical attachments

1. In cross-sections, in the textual description of materialization, the position **RK2** - flat roof above the heated space-roof terrace, the thermal insulation is being modified - **instead of the stone wool, XPS is being added.**

Sheets in tehcnical documentation:

Block 1 – sheet no 2017 U003 PZI A01 9

sheet no 2017 U003 PZI A01 10

Block 2 – sheet no 2017 U003 PZI A01 9

sheet no 2017 U003 PZI A01 10

Block 3 – sheet no 2017 U003 PZI A01 46

2. Modification of graphical attachments – Detail: Brick wall – Roof terrace on the 2nd floor, **instead of stone wool, XPS is being added.**

Sheets in technical documentation:

Block 1 – sheet no 2017 U003 PZI A01 19-7

Block 2 – sheet no 2017 U003 PZI A01 19-7

Block 3 – sheet no 2017 U003 PZI A01 56-7

All other terms and conditions of the Tender Dossier remain unchanged.

The above mentioned modifications form an integral part of the Tender Dossier, and will be sent by e-mail to all the potential tenderers who have submitted request for receipt of Tender Dossier, under the name RHPW5ABIOP22017boq1.

Procurement committee

